

Monthly water sampling (EPL Point 4 - pit receiving drainage from vegetated filter basin, NE corner of site)

Sampling Date	Date data obtained	Date data published on website	pH	Total Suspended Solids (mg/L)	Comments/justification	EPL limits		Sample compliant with EPL limits?	
						pH	TSS (mg/L)	pH	TSS
27/03/2020	2/04/2020	Unknown	7.8	350	NA	6.5-8.5	50	YES	NO
29/04/2020	5/05/2020	19/05/2020	8.1	14	NA	6.5-8.5	50	YES	YES
29/05/2020	10/06/2020	Unknown	6.7	<2	NA	6.5-8.5	50	YES	YES
30/06/2020	NA	Unknown	NA	NA	Discharge point dry during all inspections	6.5-8.5	50	NA	NA
14/07/2020	17/07/2020	Unknown	7.4	200	Discharge after heavy rainfall conditions	6.5-8.5	50	YES	NO
17/07/2020	17/08/2020	Unknown	NA	76	Normal conditions. pH not analysed as sample submitted outside of holding time.	6.5-8.5	50	NA	NO
10/08/2020	14/08/2020	26/08/2020	7.8	50	Approx. 15 mm rain in preceding days. Swale moist. No odour. Water running.	6.5-8.5	50	YES	YES



Date Produced: 31/03/2020  
 Basemap Imagery: NSW Globe, © Department Finance, Services & Innovation [07/04/2018]  
 (Used under Creative Commons <https://creativecommons.org/licenses/by/3.0/au/legalcode>)

